



**U.P. Pollution Control Board**

**CONSENT ORDER**

**Ref No. -  
2390/UPPCB/Noida(UPPCBRO)/CTO/water/NOI  
DA/2018**

**Dated : 03/02/2018**

**To ,**

M/S Saurabh Choudhry  
ICARE eye hospital and Post Graduate Institute  
E-3A, SECTOR 26, NOIDA, GAUTAM BUDH NAGAR, UP  
NOIDA

**Sub : Consent under Section 25/26 of The Water (Prevention and control of Pollution) Act, 1974 (as amended) for discharge of effluent to M/s. ICARE eye hospital and Post Graduate Institute**

**Reference Application No :142694**

**Dated :03/02/2018**

1. For disposal of effluent into water body or drain or land under The Water (Prevention and control of Pollution) Act,1974 as amended (here in after referred as the act ) M/s. ICARE eye hospital and Post Graduate Institute is hereby authorized by the board for discharge of their industrial effluent generated through ETP for irrigation/river through drain and disposal of domestic effluent through septic tank/soak pit subject to general and special conditions mentioned in the annexure ,in refrence to their foresaid application .
2. This consent is valid for the period from 01/01/2018 to 31/12/2021 .
3. In spite of the conditions and provisions mentioned in this consent order UP Pollution Control Board reserves its right and powers to reconsider/amend any or all conditions under section 27(2) of the Water (Previntion and Controt of Pollution) Act, 1974 as amended .

This consent is being issued with the permission of competent authority .

**For and on behalf of U.P. Pollution Control Board**

**Regional Officer  
NOIDA**

**Enclosed : As above  
(condition of consent):**

Copy to: Chief Environmental Officer (Circle-1), U.P. Pollution Control Board, Lucknow.

**Regional Officer  
NOIDA**

## U.P. POLLUTION CONTROL BOARD, LUCKNOW

### Annexure to Consent issued to M/s.ICARE eye hospital and Post Graduate Institute vide

Consent Order No. 142694/ Water

Dated : 03/02/2018

#### CONDITIONS OF CONSENT

1. This consent is valid only for the approved production capacity of EYE HOSPITAL.
2. The quantity of maximum daily effluent discharge should not be more than the following :

<b>Effluent Discharge Details</b>			
<b>S.No</b>	<b>Kind of Effluent</b>	<b>Maximum daily discharge,KL/day</b>	<b>Treatment facility and discharge point</b>
1	Domestic	16 K.L.D.	STP

3. Arrangement should be made for collection of water used in process and domestic effluent separately in closed water supply system. The treated domestic and industrial effluent if discharged outside the premises, if meets at the end of final discharge point, arrangement should be made for measurement of effluent and for collecting its sample. Except the effluent informed in the application for consent no other effluent should enter in the said arrangements for collection of effluent. It should also be ensured that domestic effluent should not be discharged in storm water drain .
- 4 a. The domestic effluent should be treated in treatment plant so that the should be in conformity with the following norms dated treated effluent .

<b>Domestic Effluent</b>		
<b>S.No</b>	<b>Parameter</b>	<b>Standard</b>
1	Total Suspended Solids	100 mg/liter
2	BOD	30 mg/liter
3	COD	250 mg/liter
4	Oil & Grease	10 mg/liter

- 4 b. The industrial effluent should be treated in treatment plant so that the treated effluent should be in conformity with the following norms. .

<b>Industrial Effluent</b>		
<b>S.No</b>	<b>Parameter</b>	<b>Standard</b>

- 5 . Effluent generated in all the processes, bleed water, cooling effluent and the effluent generated from washing of floor and equipments etc should be treated before its disposal with treated industrial effluent so that it should be according to the norms prescribed under The Environment (Protection) Act,1986 or otherwise mandatory .
- 6 . The other pollutant for which norms have not been prescribed, the same should not be more than the norms prescribed for the water used in manufacturing process of the industry .
- 7 . The method for collecting industrial and domestic effluent and its analysis should be as per legal Indian standards and its subsequent amendments/standards prescribed under The Environment (Protection) Act, 1986.
- 8 . The treated domestic and industrial effluent be mixed (as per the provisions of Condition No. 2) and disposed of on one disposal point. This common effluent disposal point should have arrangement for flow meter/V Notch for measuring effluent and its log book be maintained .

#### Specific Conditions:

1. This Consent order is valid for M/S I CARE eye hospital and Post Graduate Institute, E-3A, Sector -26, Noida, Gautam Buddh Nagar and valid up to 31.12.2019.
2. Hospital shall obtain permission from Central Ground Water Authority for abstraction of ground water.
3. Hospital shall ensure proper operation and maintenance of Effluent Treatment Plant and Sewage Treatment Plant. Also, independent flow meters, logbook and electric meter should be installed for treatment plants.
4. Hospital shall submit quarterly analysis reports of all installed effluent treatment plant and sewage treatment plant from a certified/approved laboratory.
5. Hospital shall ensure adequate plantation and green belt within its premises. Green cover shall be in compliance of approved map from concerned Authority.
6. Hospital shall comply with Waste Management Rules notified by MoEF & CC i.e. Plastic Waste Management Rules, 2016, Solid Waste Management Rules, 2016, Hazardous and Other Waste (Management and Transboundary) Rules, 2016 Bio Medical Waste (Management & Handling) Rules-2016 (as applicable).
7. Hospital shall submit annual returns as per above mentioned rules. Also, Environmental Statement in prescribed form as per Rule 14 of Environment (Protection) Act, 1986.
8. Hospital shall make rain water harvesting on the premises as per map approved by concerned Authority. Pre and Post-monsoon maintenance of rain water harvesting pit shall be done annually.
9. Hospital shall abide by directions given by Hon'ble Supreme Court, High Court, National Green Tribunal, Central Pollution Control Board and Uttar Pradesh Pollution Control Board for protection and safeguard of environment from time to time.
10. Hospital has to submit balance consent (WATER) fee (IF ANY) within one month of getting this consent.

**Issued with the permission of competent authority .**

**For and on behalf of U.P. Pollution Control Board .**

**Regional Officer  
NOIDA**